

Certificate of Type-examination

No.: 07229030/AA/00

Telefication declares that the stated alarm equipment complies with the Technical specifications as listed in Annex 2 of this certificate.

Product description: **Controller/Control panel interface expansion unit**
Trademark: **SATEL**
Family name: --
Type designation: **ACX-100**
Serial No: --
Hard- / Softw. release No: **1.2 / 1.0**

Manufacturer: **SATEL sp. z o.o.**
Address: **Schuberta 79**
City: **80-172 Gdansk**
Country: **Poland**

This certificate is granted to:

Name: **SATEL sp. z o.o.**
Address: **Schuberta 79**
City: **80-172 Gdansk**
Country: **Poland**

This certificate has THREE Annexes.

Zevenaar, 18 June 2010



W.J.M. Jong
Operations Manager
Certification



Remarks and observations

The following conditions are applicable:

Equipment Security Grade: 2
Equipment Environmental Class: II
Equipment Class: Fixed

According to EN 50131-1:2006 and A1:2009, this equipment can be applied in installed systems up to and including Security Grade 2.

This certificate does not cover the electrical safety aspects of TS 50131-3.

Documentation lodged for this type-examination

Test Reports:

- Telefication B.V.: 99784880 - Rev. 1.0, 16 June 2010

Product Documentation:

- Assembly drawings
- Bill of materials
- Electric diagrams
- Photos
- User manual

Technical Standards and Specifications

The product shows no non-compliances with:

- | | |
|-----------------|---------------|
| - EN 50130-4 | December 1995 |
| - EN 50130-4/A1 | April 1998 |
| - EN 50130-4/A2 | January 2003 |
| - TS 50131-3 | July 2003 |

Technical features and characteristics

The product includes the following features and characteristics:

Not specified

The product as described in this Certificate includes the following type designations:

Product description:	Controller/Control panel interface expansion unit
Type designation:	ACX-100
Trademark:	SATEL
Serial No:	--
Hard- / Softw. release No:	1.2 / 1.0